



Thermal Assessment Report

Plant Name
City, State

Prepared On:
11/09/2018

Prepared By:
Name - Title
Rep Company

Armstrong International

INTELLIGENT SOLUTIONS IN STEAM, AIR AND HOT WATER

816 Maple Street, Three Rivers, Michigan 49093 Phone: (269) 273-3415 Fax: (269) 273-8742



Thermal Assessment Report

Notice

This report has been submitted to Plant Name (Name), in City, State as the Recipient in confidence and it contains trade secrets, as well as privileged information, and/or proprietary work product of Armstrong International, Inc. (Armstrong). In consideration of the receipt of this report and the information and data herein, the Recipient agrees that it will use this document and the information contained herein only for internal use and for the purpose of evaluating Energy Conservation, Safety Measures or other work proposed to be performed by Armstrong (collectively, the "Work"). The Recipient agrees that it will not disclose this report or any part thereof to any third parties, and the Recipient may only disclose this document to those employees involved in the evaluation of the Work on an as-needed basis. The Recipient may make only those copies needed for such internal review.

Armstrong International

INTELLIGENT SOLUTIONS IN STEAM, AIR AND HOT WATER

816 Maple Street, Three Rivers, Michigan 49093 Phone: (269) 273-3415 Fax: (269) 273-8742



TABLE OF CONTENTS

1. INTRODUCTION
2. UTILITIES AND STEAM SYSTEM
3. OBSERVATIONS
4. ASSESSMENT RESULTS / VERIFICATIONS COMPLETED DURING THE AUDIT
5. CLOSING

Armstrong International

INTELLIGENT SOLUTIONS IN STEAM, AIR AND HOT WATER

816 Maple Street, Three Rivers, Michigan 49093 Phone: (269) 273-3415 Fax: (269) 273-8742



Thermal Assessment Report

1. INTRODUCTION

Armstrong/Rep conducted a Thermal Assessment of the steam and condensate systems at Plant, City, State on Month Date, 20XX.

We appreciate the opportunity to visit your facility and the time and knowledge of your team helping us and making it possible to conduct this assessment.

The following areas were assessed:

- Overall Utilities (metering, management and benchmarking)
- Steam Generation (boilers, efficiency, deaeration, blowdown)
- Steam Distribution (headers, pressure reducing valves, piping practices, leaks, insulation, steam traps)
- Steam Utilization (all users including but not limited to heat exchangers, tanks, tracers, coils)
- Condensate Collection and Return (high pressure and low-pressure headers, receivers, trapping systems, water hammer and back pressure issues)
- Hot Water Generation, Distribution, and Use
- Air Conditioning and Air Heating

The objective of the assessment was to:

- Collect up to date information for the steam and condensate systems and their operation
- Identify opportunities to improve the efficiency of the existing systems resulting in the conservation of fuel, treated water, chemicals, and reducing CO2 emissions
- Identify opportunities to improve the system's safety, reliability, and integrity

Abbreviations used in the Observation Section:

Energy - Fuel, Water, Sewer, Electricity
M&R - Maintenance and Reliability
Prod - Production and Product thru-put
Safety - Safety

Armstrong International

INTELLIGENT SOLUTIONS IN STEAM, AIR AND HOT WATER

816 Maple Street, Three Rivers, Michigan 49093 Phone: (269) 273-3415 Fax: (269) 273-8742



Armstrong Thermal Assessment Report

2. UTILITIES AND STEAM SYSTEM

Site Energy Information

Company Name					Date	Aug-18		
Address								
City			State	ZIP	Phone			
Name / Title					e-mail			
Name / Title					e-mail			
Utilities Cost Information					Facility details			
Utility	Cost		Total Consumption		Annual cost	Production		
	Unit Cost	Units	Qty	Units	\$/year	Total Capacity		
Raw Water:		\$/kgal		kgal		Operation		
Treated Water	6.55	\$/kgal	5514.5	kgal	\$ 36,106	Operation		
Sewer 1	5.72	\$/kgal	5514	kgal	\$ 31,548	Operation		
Chem Treatment						Shutdown Date		
Primary Fuel	4.22	\$/MMBtu	530240	MMBTU	\$ 225,057	Cogeneration and Steam Generated as By-product		
Back Up Fuel	4.00	\$/gal	4092	MMBTU	\$ 16,377	Power Generation Capacity		
If fueloil #6, S%		%				Heat Recovery - Steam		
Electricity	0.0623	\$/kWh	2844	MWh	\$177,117	- Hot water		
Own/Purchased Steam		\$/klb		klb		Steam as by-product?		
Steam Generation					Major Steam Users			
Boilers #	Units	1	2	3	4	Equipment		
Manufacturer		Johnston				(fill details in next tab)		
Year		1998				Flow		
Type	WT/FT	FT	FT			lb/h		
Rated Capacity	HP	150	100			Pressure		
Rated Pressure / Temp	Psig / F					Psig		
Operating Press/Temp	Psig / F	150	125			Operation		
Avg. Firing Rate	0 - 100%					Cont/Batch		
Main Fuel Used		Natural Gas	Natural Gas			Tanks		
Back-up Fuel						Tracers		
% Back-up Fuel Used	0 - 100%					Rail Cars		
Flue Gas - O ₂ %	0 - 21%	Not available	Not available					
Flue Gas Temperature	F	370	Not available					
Economizer	Yes/No	No	No					
Air Preheater (Yes/No)	Yes/No	No	No					
D/A Pressure	Psig	8						
Feed Water Temperature	F	225						
Boiler Efficiency	%	NA	NA					
Boiler House Efficiency	%	NA						
Boiler Blowdown	%	10-25%	BD Heat r	Yes / No	No			
Feed Water/Make Up Water/Condensate Quality					Condensate Return System			
	Units	Condensate	MUW	FW	Boiler	Condensate Returned		
Oil content	mg/l					%		
Conductivity	µS/cm			500-700	2500-5500	Psig		
Ferric Oxides	µg/l					F		
pH	-					Where is Condensate Returned To?		
						To Condensate Tank		
						How is Condensate Returned?		
						By Mechanical Pump		
Hot Water Generation					Hot Water System #			
						1		
						2		
						3		
						Method of production		
						Capacity installed		
						MMBTU/hr		
						Temperature		
						F		
						Once Trough/Closed Loop		
						OT or CL		
						Average Hot Water Production		
						kgal/day		

Armstrong International

INTELLIGENT SOLUTIONS IN STEAM, AIR AND HOT WATER

816 Maple Street, Three Rivers, Michigan 49093 Phone: (269) 273-3415 Fax: (269) 273-8742



Armstrong Thermal Assessment Report

Steam Distribution System

Distribution Header #		1	2	3
Head. Pressure	Psig	125	150	
Head. Temperature	F	saturated	saturated	
Winter Flow Rate (average)	klb/h	NA	Peak:	
Summer Flow Rate (average)	klb/h	NA	Peak:	
Est. No. of Steam Traps		350		
Date of Last Trap Survey		Not Available		
Estim. % failure		>15%		

Major Hot Water Users

Equipment	Flow	Water Temperature	Operation
	gpm	F	Direct Injection/Once Trough/Closed loop

Projects (What Energy Projects Are Known But Not Funded - Any Additional Comments)




1
2
3

Armstrong International




INTELLIGENT SOLUTIONS IN STEAM, AIR AND HOT WATER

816 Maple Street, Three Rivers, Michigan 49093 Phone: (269) 273-3415 Fax: (269) 273-8742

3. OBSERVATIONS

	<table border="1"> <tr> <td>Issue:</td> <td colspan="4">Condensate Receiver Venting</td> </tr> <tr> <td>Category:</td> <td>Energy</td> <td>Safety</td> <td>M & R</td> <td></td> </tr> <tr> <td>Location:</td> <td colspan="4">All condensate receivers</td> </tr> <tr> <td colspan="5">Excessive steam venting at the condensate receiver vent. Venting steam is a waste of heat (fuel), treated water and chemicals. If recovered the vented steam will save energy and water.</td> </tr> </table>	Issue:	Condensate Receiver Venting				Category:	Energy	Safety	M & R		Location:	All condensate receivers				Excessive steam venting at the condensate receiver vent. Venting steam is a waste of heat (fuel), treated water and chemicals. If recovered the vented steam will save energy and water.				
Issue:	Condensate Receiver Venting																				
Category:	Energy	Safety	M & R																		
Location:	All condensate receivers																				
Excessive steam venting at the condensate receiver vent. Venting steam is a waste of heat (fuel), treated water and chemicals. If recovered the vented steam will save energy and water.																					
	<table border="1"> <tr> <td>Issue:</td> <td colspan="4">Condensate Receiver Venting</td> </tr> <tr> <td>Category:</td> <td>Safety</td> <td>Energy</td> <td>M & R</td> <td></td> </tr> <tr> <td>Location:</td> <td colspan="4">Main Process Condensate Receiver</td> </tr> <tr> <td colspan="5">Excessive venting and liquid draining through the receiver vent due to undersized pump. Draining 210F water is a safety concern . The pressurized stream of hot water and steam deteriorates the concrete</td> </tr> </table>	Issue:	Condensate Receiver Venting				Category:	Safety	Energy	M & R		Location:	Main Process Condensate Receiver				Excessive venting and liquid draining through the receiver vent due to undersized pump. Draining 210F water is a safety concern . The pressurized stream of hot water and steam deteriorates the concrete				
Issue:	Condensate Receiver Venting																				
Category:	Safety	Energy	M & R																		
Location:	Main Process Condensate Receiver																				
Excessive venting and liquid draining through the receiver vent due to undersized pump. Draining 210F water is a safety concern . The pressurized stream of hot water and steam deteriorates the concrete																					
	<table border="1"> <tr> <td>Issue:</td> <td colspan="4">Excessive Blowdown and No Heat Recovery</td> </tr> <tr> <td>Category:</td> <td>M & R</td> <td>Prod</td> <td>Safety</td> <td>Energy</td> </tr> <tr> <td>Location:</td> <td colspan="4">Boiler room</td> </tr> <tr> <td colspan="5">The heat of the continuous blowdown is not recovered and is lost to the atmosphere. Also, cold city water is added to reduce the temperature before the drain. Better control of the blowdown rates and recovering the heat of the blowdown can substantially reduce the water usage and the energy losses, as the water temperature is the same as the temperature of the steam generated in the boiler.</td> </tr> </table>	Issue:	Excessive Blowdown and No Heat Recovery				Category:	M & R	Prod	Safety	Energy	Location:	Boiler room				The heat of the continuous blowdown is not recovered and is lost to the atmosphere. Also, cold city water is added to reduce the temperature before the drain. Better control of the blowdown rates and recovering the heat of the blowdown can substantially reduce the water usage and the energy losses, as the water temperature is the same as the temperature of the steam generated in the boiler.				
Issue:	Excessive Blowdown and No Heat Recovery																				
Category:	M & R	Prod	Safety	Energy																	
Location:	Boiler room																				
The heat of the continuous blowdown is not recovered and is lost to the atmosphere. Also, cold city water is added to reduce the temperature before the drain. Better control of the blowdown rates and recovering the heat of the blowdown can substantially reduce the water usage and the energy losses, as the water temperature is the same as the temperature of the steam generated in the boiler.																					

Excessive Blowdown and No Blowdown Heat Recovery

	<table border="1"> <tr> <td>Issue:</td> <td colspan="4">Condensate Return Line connected to Drain</td> </tr> <tr> <td>Category:</td> <td>M & R</td> <td>Prod</td> <td>Safety</td> <td>Energy</td> </tr> <tr> <td>Location:</td> <td colspan="4">Blowdown drain line</td> </tr> </table> <p>Condensate return line connected to the drain is a waste of heat (fuel), treated water and chemicals. If recovered the condensate will save energy, water and sewer charges. The valve was closed after the discovery.</p>	Issue:	Condensate Return Line connected to Drain				Category:	M & R	Prod	Safety	Energy	Location:	Blowdown drain line			
Issue:	Condensate Return Line connected to Drain															
Category:	M & R	Prod	Safety	Energy												
Location:	Blowdown drain line															
	<table border="1"> <tr> <td>Issue:</td> <td colspan="4">Missing Insulation</td> </tr> <tr> <td>Category:</td> <td>M & R</td> <td>Prod</td> <td>Safety</td> <td>Energy</td> </tr> <tr> <td>Location:</td> <td colspan="4"></td> </tr> </table> <p>Insulation is missing or damaged. There will be greater heat transfer losses through radiation and convection resulting in fuel waste. Also, due to the heat losses, steam will condense faster which can lead to water hammer.</p>	Issue:	Missing Insulation				Category:	M & R	Prod	Safety	Energy	Location:				
Issue:	Missing Insulation															
Category:	M & R	Prod	Safety	Energy												
Location:																
	<table border="1"> <tr> <td>Issue:</td> <td colspan="4">Undersized Drip Leg and Missapplied Drip Trap</td> </tr> <tr> <td>Category:</td> <td>M & R</td> <td>Prod</td> <td>Safety</td> <td>Energy</td> </tr> <tr> <td>Location:</td> <td colspan="4">Near 150 HP Boiler</td> </tr> </table> <p>The drip legs are main components of the steam distribution system, assuring the quality of the steam at the point of usage. They are provided to:</p> <ul style="list-style-type: none"> • Let condensate escape by gravity from the fast moving steam • Store condensate until the pressure differential can discharge through the steam trap <p>If not properly installed or sized, the condensate cannot be removed from the steam headers and the quality of the steam deteriorates. Wet steam can induce water hammer or damage valves and equipment.</p>	Issue:	Undersized Drip Leg and Missapplied Drip Trap				Category:	M & R	Prod	Safety	Energy	Location:	Near 150 HP Boiler			
Issue:	Undersized Drip Leg and Missapplied Drip Trap															
Category:	M & R	Prod	Safety	Energy												
Location:	Near 150 HP Boiler															



Thermal Assessment Report

4. ASSESSMENT RESULTS / VERIFICATIONS COMPLETED DURING THE AUDIT

Potential Optimization	Comment
OVERALL STEAM SYSTEM PROFILE	
Steam System - Measurements and Monitoring	To be Improved
Steam Generation	To be Improved
Fuel	To be Improved
Feedwater	To be Improved
Make-up Water	To be Improved
Steam Distribution - to plant, to areas and/or to individual users	To be Improved
Costs Tracking - fuel, water, sewer, chemicals, steam	To be Improved
Safety	To be Improved
BOILER HOUSE	
Boiler Efficiency - is it measured or calculated?	No
Stack temperature	Not Available
Oxygen in flue gas	Not Available
Combustion Air Supply Temperature	To be Improved
Boiler/Burner Tune-Up	Not Available
Steam Pressure Setting	OK
Gauges and Instrumentation	To be Improved
Boiler Sizing and Reliability	To be Improved
Steam Quality	To be Improved
Boiler Blow-Down Rate	To be Improved
Boiler Blow-Down Recovery	To be Improved
Deaerator Pressure	OK
Feed Water Temperature	OK
Heat Recovery - MUW Pre-Heating	To be Improved
Vents	To be Improved
STEAM DISTRIBUTION	
Proper Piping Practices	To be Improved
Water Hammer	To be Improved
Steam Quality	To be Improved
External Leaks of Steam or Condensate from Pipes, Flanges, etc.	To be Improved
Steam Pressure	To be Improved
Internal Leaks	To be Improved
Insulation	To be Improved
Steam Traps and Steam Trap Management	To be Improved

Armstrong International

INTELLIGENT SOLUTIONS IN STEAM, AIR AND HOT WATER

816 Maple Street, Three Rivers, Michigan 49093 Phone: (269) 273-3415 Fax: (269) 273-8742



Thermal Assessment Report

STEAM USERS	
Steam Users / Heat Exchangers Performance - Stall, Air Locked, Vacuum	To be Improved
Point of Use Pressure	OK
Piping Practices - Users	To be Improved
CONDENSATE AND FLASH STEAM RECOVERY	
Condensate Return - Quantity and Quality	To be Improved
Condensate Return Piping Practices and Sizing	To be Improved
Water Hammer	To be Improved
Flash Steam Recovery/Utilization	To be Improved
HOT WATER	
Hot Water Generation (once through) - Domestic HW, Once Through Hoses	Not Applicable
Hot Water Generation (Recirculation) - HW for Heating, For Process	Not Applicable
Hot Water Distribution	Not Applicable
Hot Water Use	Not Applicable
HVAC	
HVAC - AHU, Unit Heaters, Make-up Air	Not Applicable
Humidification	Not Applicable

Armstrong International

INTELLIGENT SOLUTIONS IN STEAM, AIR AND HOT WATER

816 Maple Street, Three Rivers, Michigan 49093 Phone: (269) 273-3415 Fax: (269) 273-8742



Armstrong® Thermal Assessment Report

5. CLOSING

Rep/Armstrong appreciates the opportunity to assist Plant with the thermal assessment of the steam and condensate systems and welcomes the opportunity to be Plant's partner.

We are pleased to report there is potential for improvement in the areas of safety, reliability, and energy and water waste. During this assessment, the following opportunities were identified:

- Improve the condensate return system

There are multiple locations where the condensate is drained and vents are blowing flash steam and water. An properly designed and operating system will not only reduce costs (makeup water, heating and treating, and sewer charges), but will improve safety and reduce operational and maintenance issues.

- Improve piping practices

There are distribution pipes that do not have properly designed (location, size and depth) drip legs and have missapplied drip traps. Excess condensate in steam lines can erode/corrode PRVs, control valves, or any downstream fitting. It can also result in water hammer which will quickly damage fittings, valves, or heating equipment. Excessive pressure drops in the steam distribution system can also be associated with the bad steam quality

- Improve metering/monitoring

Additional meters (natural gas, water, feed water, steam) and instrumentation could be installed on strategic locations (individual boilers and/or headers) to provide the plant management with better tools to evaluate the system and its efficiency, as well as measure the results of implemented projects.

- Improve steam generation efficiency

The high boiler flue gas temperatures present an opportunity for heat recovery. Utilizing the excess heat before discharging the flue gas will improve the system efficiency. The boiler room will benefit from online oxygen monitoring, blowdown optimization and heat recovery, insulation of hot surfaces will yield substantial savings and improve safety.

Armstrong and Hatfield would welcome the opportunity to work with the facility on further analysis of the findings and their development into definitive projects.

Recommended next steps:

- Perform a site-wide steam trap survey and establish a trap/leak/insulation management program
- Training either on site or at our Armstrong facility
- System audit- a complete engineering audit in order to study in details the technical feasibility and the economic interest of each one of the above opportunities
- Develop a Monitoring plan

Armstrong International

INTELLIGENT SOLUTIONS IN STEAM, AIR AND HOT WATER

816 Maple Street, Three Rivers, Michigan 49093 Phone: (269) 273-3415 Fax: (269) 273-8742